


AQUA DRILLING SERVICES LTD.

2135



DOMESTIC IRRIGATION EXPLORATION

BE "WELL" SATISFIED

G.S.T. REG. #100240324

 BOX 4827
 WILLIAMS LAKE, B.C.
 V2G 2V8
 PHONE: 392-2241
NAME: B.C. MINISTRY LAND WATER + AIR.ADDRESS: 400-640 BORLAND ST WIL.WELL LOCATION: BOWRON LAKE PARK.

LOT _____ BLOCK _____ SEC. _____

TWP _____ RANGE _____ PLAN _____

PROPOSED USE: DOMESTIC ☒ INDUSTRIAL _____ MUNICIPAL _____
IRRIGATION _____ TEST WELL _____ OTHER _____

TYPE OF WORK: OWNER'S NUMBER OF WELL (IF MORE THAN ONE) _____

NEW WELL ☒ AIR ROTARY ☒

DEEPEMED _____ ROTARY _____

RECONDITIONED _____ JETTED _____

CABLE _____

DIMENSIONS: DIAMETER OF WELL 6 INCHESDRILLED 73 FT. DEPTH OF COMPLETED WELL 73 FT.

CONSTRUCTION DETAILS:

CASING INSTALLED: 6 3/4" DIAM. FROM 0 FT. TO 72 FT.

THREADED _____ " DIAM. FROM _____ FT. TO _____ FT.

WELDING _____ " DIAM. FROM _____ FT. TO _____ FT.

PERFORATIONS: YES _____ NO ☒

TYPE OF PERFORATOR USED _____

SIZE OF PERFORATIONS _____ IN. BY _____ IN.

PERFORATIONS FROM _____ FT. TO _____ FT.

PERFORATIONS FROM _____ FT. TO _____ FT.

SCREENS: YES ☒ NO _____MANUFACTURER'S NAME: JOHNSONTYPE: TELESCOPE MODEL NO. _____DIAM. 1 1/2 SLOT SIZE 40 FROM 72 FT. TO 73 FT.

DIAM. _____ SLOT SIZE _____ FROM _____ FT. TO _____ FT.

GRAVEL PACKED: YES _____ NO ☒ SIZE OF GRAVEL _____

GRAVEL PLACED FROM _____ FT. TO _____ FT.

SURFACE SEAL: YES ☒ NO _____ TO WHAT DEPTH 20 FT.MATERIAL USED IN SEAL: BEN SEALMETHOD OF SEALING STRATA OFF: STEEL CASING

PRODUCTION DATA AT TIME OF DRILLING:

STATIC LEVEL 15 FT.MEASURED FROM 0 FT. WITH AIR _____ PUMP _____ OTHER _____PUMPING LEVEL 60 FT. AT 25 GPMRECOMMENDED PUMP SETTING 60 FT.

IF FLOWING WELL _____ GPM

RECOMMENDED MAX. PUMP OUTPUT 12 GPMWATER CLEAR ☒ COLORED ☒ SILT _____ SAND _____DURATION OF TEST 3 HRS.DATE: STARTED MAR 14/05 COMPLETED MAR 18/05

RIG # _____ OTHER EQUIP. _____

DEPTH:

OVERBURDON 73 FT. TOOL PUSH _____BEDROCK _____ FT. DRILLER H. HURALLTOTAL 73 FT. HELPER F. DEEVEE R.

FORMATION:

DEPTH:

FROM	TO	
GROUND LEVEL		
0	2	FILL
2	6	BLACK LOAM
6	25	BLUE SILTY CLAY
25	49	SILTY CLAY
49	71	BROKEN ROCK + SILT
71	73	GRAVEL
73		CLAY + GRAVEL


WELL OWNER

 ALL MATERIALS USED WILL REMAIN THE PROPERTY OF AQUA DRILLING SERVICES LTD
 UNTIL ACCOUNT HAS BEEN PAID IN FULL. I AUTHORIZE AQUA DRILLING SERVICE
 LTD. ACCESS TO RECLAIM PIPE, SCREENS, ETC., IN THE EVENT OF NON PAYMENT.

 I _____ HERE BY AGREE WORK HAS BEEN
 COMPLETED IN ACCORDANCE WITH THIS CONTRACT.
AQUA DRILLING SERVICES LTD. REP. [Signature]

GENERAL REMARKS:

74' TOTAL CASINGDOE TO SILTY COLOUR RANPUMP TEST AT 12 G.P.MFOR 6 HRS. STATIC LEVEL 20 FTWATER CLEARED AFTER 1 HR. TEST
 IT IS HERE BY AGREED THAT FORMATIONS, QUALITY, QUANTITY & TYPE OF WATER, ALONG WITH ALL OTHER REMARKS, ARE TRUE ONLY TO THE BEST KNOWLEDGE OF TH
 PERSONNEL & COMPANY, AND THEY CANNOT BE HELD RESPONSIBLE FOR A MISTAKE IN CALCULATIONS.
 THE COMPANY WILL NOT BE HELD RESPONSIBLE FOR PUBLIC LIABILITY OR PROPERTY DAMAGE CAUSED BY FLOWING WELL WASH OUTS OR ANY OTHER MISHAPS.



Bowron Lk. Rd

Bowron Lk 2006

Reg
Centre →

Parking lot

STOP
SIGN

Bowron Lk
Well

25.2m

Power
Box

3m

8m

Culvert

26m

Culvert

Bowron Lk Front Country Campsite